

FIRE

C-0035-2014, Skiffes Creek Switching Station

FM, Kendall L. Driscoll Jr.

June 5, 2015

Fire has no objections to this as a conceptual plan.

However, fire has the following concerns:

1. Fire apparatus access to the facility.
2. Security against unauthorized entry.
3. Water supply for anticipated fire suppression.
4. Emergency management plans.